Eaton Electrical Products Ltd

Llantarnam Park, Cwmbran South Wales, NP44 3AW Tel: +44 (0) 1633 628500 Fax: +44 (0) 1633 866346 Email: <u>Firecustomerservices@eaton.com</u>

Web: www.eaton.com



DECLARATION OF PERFORMANCE

No DoP0442

Unique identification code of the product-type:			
Symphoni Voice+ Range (SYV+, SYV+/WP, SYV+/AV, SYV+/AV/WP)			
Intended use/es:			
Fire detection and fire alarm systems			
Manufacturer:			
Eaton Electrical Products Ltd, Llantarnam Park, Cwmbran, South Wales, NP44 3AW, United Kingdom			
Authorised representative:			
Not Applicable			
System/s of AVCP:			
System 1			
Harmonised standard/s:			
EN54-3:2001+A1:2002+A2:2006			
N-CG-11-1-V			
Notified body/ies:			
Intertek Deutschland GmbH, Strangenstraße 1, 70771 Leinfelden-Echterdingen (0905-CPR-00113)			

Eaton Electrical Products Ltd

Llantarnam Park, Cwmbran South Wales, NP44 3AW Tel: +44 (0) 1633 628500 Fax: +44 (0) 1633 866346

Email: Firecustomerservices@eaton.com

Web: www.eaton.com



Declared performance/s:

Essential Characteristics	Performance	Harmonized Technical Specification
		EN54-3:2001 + A1:2002 + A2:2006
Performance under fire conditions	Pass	4.2, 4.3, 5.2, 5.3, C.3.1, C.3.2, C.5.1, C.5.2, C.5.3
Operational reliability	Pass	4.4, 4.5, 4.6, 5.4
Durability Of Operational Reliability, Temperature Resistance	Pass	5.5, 5.6 ⁽¹⁾ , 5.7, 5.8, 5.9
Durability Of Operational Reliability, Humidity Resistance	Pass	5.8, 5.9, 5.10 ⁽¹⁾
Durability Of Operational Reliability, Corrosion Resistance	Pass	5.11
Durability Of Operational Reliability, Shock and Vibration Resistance	Pass	5.12 to 5.15
Durability Of Operational Reliability, Electrical Stability	Pass	5.16
Durability Of Operational Reliability, Resistance To Ingress	Pass	5.17

⁽¹⁾ Only applicable to SYV+/WP and SY+/AV/WP

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulations (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for an on behalf of the manufacturer by:

Name: Mr Philip Williams (Approvals Manager)

Signed: PJ Www.

Place: Cwmbran Date: 11th September 2024